

# CERTIFICATE OF COMPLIANCE

Certificate Number 20180105-R39344  
Report Reference R39344-20171229  
Issue Date 2018-JANUARY-05

Issued to: Al Khalefah Factory for Metal Industries  
Al Kharj Rd, New Industrial Area  
Riyadh 14335 SAUDI ARABIA

This is to certify that  
representative samples of

SWINGING-TYPE FIRE DOORS, POSITIVE-PRESSURE  
TESTED , Complementary Product Category SWINGING-  
TYPE FIRE DOORS

USC - A single swinging type fire door assembly of the steel  
covered composite type.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10C - Positive Pressure Fire Tests of Door  
Assemblies  
ANSI/UL 10B - Fire tests Of Door Assemblies

Additional Information: See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

